

Copy

REQUA & JACKSON
Architects

614 B Street, San Diego, Cal.,

Feb. 21, 1923.

Mr. J. C. Harper, Agent
La Jolla, California.

Dear Mr. Harper:-

I have your letter of the 16th, with enclosure, and have carefully noted the contents.

I cannot feel that a mistake was made in specifying flush valve toilets for Torrey Pines Lodge. It is generally considered that such toilets are the best for all public places such as schools, hotels, comfort stations and so forth.

It is unfortunate that the water supply pipe to the Torrey Pines Lodge is an old rusty pipe, full of scale. Also that there are three globe valves in the pipe, between the reservoir and the Lodge, each one of which reduces the rate of flow.

I believe that all concerned were cognizant of the fact that this type of toilet was specified and it seems a fair assumption that arrangements would be made with the city for a proper supply pipe, especially in view of the large amounts of water that would be required for the grounds about the Lodge.

The size of pipe listed in the catalog for 9 flush valve toilets with 30 lbs. pressure, is $1\frac{1}{2}$ inch diameter. With the tank at the reservoir full of water, and a supply pipe free from scale and without the globe valves in it, these flush valves would have worked satisfactorily.

However, I have no desire to enter a controversy over the matter. I have absolute confidence in your sense of justice and fairness and I shall unhesitatingly accept whatever decision you and Messrs. Morley and Klauber arrive at in the premises.

Sincerely yours,

H. L. Jackson.