

DEPARTMENT OF PUBLIC HEALTH

ROOM 5, CITY HALL  
SAN DIEGO, CALIFORNIA

September 2nd, 1925.

Mr. Guy Flemming,  
Scripps Institute for Biological Research,  
Long Beach, La Jolla, Calif.

Dear Sir :

A recent inspection of the wooden privies located on property at the foot of Torrey Pines Grade, and owned by Miss Scripps, discloses that said toilets are in a very unsanitary condition.


The maintenance of privies in the City of San Diego is prohibited by law. If a toilet is installed in San Diego, it must be one of the water flushed type, properly trapped and vented and connected to a properly constructed Cesspool or Septic Tank.

If you don't care to make these toilets comply with the ordinance governing same, it will be necessary for you to have the present structures removed and the pits filled with earth.

Please give this your immediate attention and notify this office of progress.

I have been advised you are managing this property, so take this opportunity of having this condition remedied.

Respectfully,



Plumbing Inspector.

EB:W.