

**Water Quality Chemistry Services
 2023 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	SMCL	Action Level	NL	PHG	MCLG	DLR (MRL)
1,1,1,2-Tetrachloroethane	ppb							0.5
1,1,1-Trichloroethane (1,1,1-TCA) ^A	ppb	200				1000	200	0.5
1,1,2,2-Tetrachloroethane ^A	ppb	1				0.1		0.5
1,1,2-Trichloroethane (1,1,2-TCA) ^A	ppb	5				0.3	3	0.5
1,1-Dichloroethane (1,1-DCA) ^A	ppb	5				3		0.5
1,1-Dichloroethylene (1,1-DCE) ^A	ppb	6				10	7	0.5
1,1-Dichloropropene	ppb							0.5
1,2,3-Trichlorobenzene	ppb							0.5
1,2,3-Trichloropropane ^A	ppt	5			5	0.7		5
1,2,4-Trichlorobenzene ^A	ppb	5				5	70	0.5
1,2,4-Trimethylbenzene ^D	ppb				330			0.5
1,2-Dichlorobenzene (o-DCB) ^A	ppb	600				600		0.5
1,2-Dichloroethane (1,2-DCA) ^A	ppt	500				400	0	500
1,2-Dichloropropane ^A	ppb	5				0.5	0	0.5
1,3,5-Trimethylbenzene ^D	ppb				330			0.5
1,3-Dichlorobenzene (m-DCB)	ppb							0.5
1,3-Dichloropropane ^A	ppb							0.5
1,4-Dichlorobenzene (p-DCB) ^A	ppb	5				6		0.5
11-chloroeicosafluoro-3-oxaundecane-1sulfonic acid (11Cl-PF3OUdS) ^F	ppt							(5)
1H,1H,2H,2H-perfluorodecane sulfonic acid (8:2FTS) ^F	ppt							(5)
1H,1H,2H,2H-perfluorohexane sulfonic acid (4:2FTS) ^F	ppt							(3)
1H,1H,2H,2H-perfluorooctane sulfonic acid (6:2FTS) ^F	ppt							(5)
2,2-Dichloropropane	ppb							0.5
2-Chlorotoluene ^D	ppb				140			0.5
4-Chlorotoluene ^D	ppb				140			0.5
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS) ^F	ppt							(2)
4,8-dioxa-3H-perfluorononanoic acid (ADONA) ^F	ppt							(3)
Alachlor (ALANEX) ^A	ppb	2				4	0	1
Aldrin	ppb							0.075
Antimony ^A	ppb	6				1	6	6
Atrazine (AATREX) ^A	ppb	1				0.15	3	0.5
Benzene ^A	ppb	1				0.15	0	0.5
Benzo(a)pyrene [PAH] ^A	ppt	200				7	0	100
Beryllium ^A	ppb	4				1	4	1
Bromobenzene	ppb							0.5
Bromochloromethane	ppb							0.5
Bromomethane (Methyl Bromide)	ppb							0.5

**Water Quality Chemistry Services
 2023 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	SMCL	Action Level	NL	PHG	MCLG	DLR (MRL)
Cadmium (Cd) ^A	ppb	5				0.04	5	1
Carbon Tetrachloride ^A	ppt	500				100	0	500
Chlordane ^A	ppt	100				30	0	100
Chloroethane	ppb							0.5
Chloromethane (Methyl Chloride)	ppb							0.5
Chlorothalonil (DACONIL, BRAVO)	ppb							
Chromium (Total Cr) ^A	ppb	50					100	10
cis-1,2-Dichloroethylene (c-1,2-DCE) ^A	ppb	6				13	70	0.5
cis-1,3-dichloropropene	ppb							0.5
Cryptosporidium (untreated water) ^E	Cysts/L						0	
Cyanide ^A	ppb	150				150	200	100
Dalapon ^A	ppb	200				790	200	10
Di(2-ethylhexyl) Adipate ^A	ppb	400				200	400	5
Di(2-ethylhexyl)phthalate (DEHP) ^A	ppb	4				12	0	3
Diazinon ^D	ppb				1.2			
Dibromochloropropane (DBCP) ^A	ppt	200				3	0	10
Dibromomethane	ppb							0.5
Dichlorodifluoromethane (Freon 12) ^D	ppb				1000			0.5
Dichloromethane (Methylene Chloride) ^A	ppb	5				4	0	0.5
Dieldrin	ppb							0.02
Diisopropyl Ether (DIPE)	ppb							
Dioxin [2,3,7,8-TCDD] ^A	ppq	30				0.05	0	5
Endosulfan Sulfate	ppb							
Endrin ^A	ppb	2				0.3	2	0.1
Endrin Aldehyde	ppb							
Ethyl Benzene ^A	ppb	300				300	700	0.5
Ethylene Dibromide (EDB) ^A	ppt	50				10	0	20
Ethyl-tert-Butyl Ether (ETBE)	ppb							0.5
Foaming Agents [MBAS] ^B	ppb		500					
Geosmin	ppb							
Giardia lamblia (untreated water) ^E	/L						0	
Heptachlor ^A	ppt	10				8	0	10
Heptachlor Epoxide ^A	ppt	10				6	0	10
Hexachlorobenzene ^A	ppb	1				0.03	0	0.5
Hexachlorobutadiene	ppb							0.5
Hexachlorocyclopentadiene ^A	ppb	50				2	50	1
Hexafluoropropylene oxide dimer acid (HFPO-DA) ^F	ppt	10					10	(5)

**Water Quality Chemistry Services
 2023 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	SMCL	Action Level	NL	PHG	MCLG	DLR (MRL)
Isopropylbenzene (Cumene) ^D	ppb				770			0.5
Lead (Pb) ^{A, C}	ppb			15		0.2	0	5
m, p- Xylenes ^A	ppb	1750				1800	10000	0.5
Mercury (Hg) ^A	ppb	2				1.2	2	1
Methoxychlor ^A	ppb	30				0.09	40	10
Methyl tert-Butyl Ether (MTBE) ^{A, B}	ppb	13	5			13		3
Molinate (ORDRAM) ^A	ppb	20				1		2
Monochloroacetic Acid (MCAA)	ppb					53	70	2
Monochlorobenzene (Chlorobenzene) ^A	ppb	70				70	100	0.5
Naphthalene ^D	ppb				17			0.5
n-Butylbenzene ^D	ppb				260			0.5
N-ethylperfluorooctanesulfonamidoacetic (NEtFOSAA) ^F	ppt							(5)
Nickel ^A	ppb	100				12		10
N-methylperfluorooctanesulfonamidoacetic (NMeFOSAA) ^F	ppt							(6)
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) ^F	ppt							(20)
n-Propylbenzene (isocumene) ^D	ppb				260			0.5
o-Xylene ^A	ppb	1750						0.5
p,p-DDD	ppb							
p,p-DDE	ppb							
p,p-DDT	ppb							
Perchlorate ^A	ppb	6				1		2
Perfluoro(2-ethoxyethane) sulfonic acid (PFEESA) ^F	ppt							(3)
Perfluoro-3-methoxypropanoic acid (PFMPA) ^F	ppt							(4)
Perfluoro-4-methoxybutanoic acid (PFMBA) ^F	ppt							(3)
Perfluorodecanoic acid (PFDA) ^F	ppt							(3)
Perfluorododecanoic acid (PFDoA) ^F	ppt							(3)
Perfluoroheptane sulfonic acid (PFHpS) ^F	ppt							(3)
Perfluoroheptanoic acid (PFHpA) ^F	ppt							(3)
Perfluorohexanesulfonic acid (PFHxS) ^{D, F}	ppt	10			3		10	(3)
Perfluorononanoic acid (PFNA) ^F	ppt	10					10	(4)
Perfluoropentane sulfonic acid (PFPeS) ^F	ppt							(4)
Perfluorotetradecanoic acid (PFTA) ^F	ppt							(8)
Perfluorotridecanoic acid (PFTrDA) ^F	ppt							(7)
Perfluoroundecanoic acid (PFUnA) ^F	ppt							(2)
p-Isopropyltoluene	ppb							
Polychlorinated Biphenyls (Total) ^A	ppt	500				90	0	500
Propachlor ^D	ppb				90			0.5

**Water Quality Chemistry Services
 2023 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	SMCL	Action Level	NL	PHG	MCLG	DLR (MRL)
sec-Butylbenzene ^D	ppb				260			0.5
Selenium (Se) ^A	ppb	50				30	50	5
Silver ^B	ppb		100					10
Simazine (PRINCEP) ^A	ppb	4				4	100	1
Styrene ^A	ppb	100				0.5	100	0.5
tert-Amyl Methyl Ether (TAME)	ppb							
tert-Butyl Alcohol (TBA) ^D	ppb				12			
tert-Butylbenzene ^D	ppb				260			
Tetrachloroethylene (PCE) ^A	ppb	5				0.06		0.5
Thallium ^A	ppb	2				0.1	0.5	1
Thiobencarb (BOLERO) ^{A,B}	ppb	70	1			42		1
Toluene ^A	ppb	150				150	1000	0.5
Total Suspended Solids (TSS)	ppm							
Toxaphene ^A	ppb	3				0.03	3	1
trans-1,2-Dichloroethylene (t-1,2-DCE) ^A	ppb	10				50	100	0.5
trans-1,3-dichloropropene	ppb					0		0.5
Trichloroethylene (TCE) ^A	ppb	5				1.7	0	0.5
Trichlorofluoromethane (FREON 11) ^A	ppb	150				1300		5
Trichlorotrifluoroethane (FREON 113) ^A	ppb	1200				4000		10
Trifluralin	ppb							
Vanadium ^D	ppb				50			
Vinyl Chloride (VC) ^A	ppt	500				50	0	500
Zinc (Zn) ^B	ppm		5					

- A Primary Standard
- B Secondary Standard
- C Action Level
- D Notification Level
- E TT
- F UCMR5