



THE HARTFORD STEAM BOILER INSPECTION AND INSURANCE COMPANY

HARTFORD CONNECTICUT

S. E. NUTT
MANAGER
JAMES FOGGO
CHIEF INSPECTOR

LOS ANGELES OFFICE
210 WEST SEVENTH STREET
LOS ANGELES 14, CALIFORNIA
March 17, 1948

REPORT OF INSPECTION

DATE OF INSPECTION March 4, 1948 INSPECTOR Wachter
LOCATION Mission Beach Plunge Mission Beach, California

Feed Water Heater No. 31233 2'8"x5'6'

This pressure vessel was carefully examined for corrosion or other deterioration, internal deposits, signs of leakage at seams and other defects. The various safety appliances were also examined.

Heat Exchangers No.1 2'11"x5'2"
Heat Exchangers No.2 1'8"x3'11"
Inspected externally while drained.

No conditions were observed that require attention at this time.

Yours very truly,

Chief Inspector

WJG:bc

Orig. to M.A.

RECEIVED
CITY CLERK'S OFFICE
MAR 18 1 47 PM 1948
SAN DIEGO, CALIFORNIA

TO City Clerk
~~Board of Supervisors~~
~~San Diego, et al~~
Civic Center Bldg.
San Diego, California